

UE



# **PRESSURE SWITCH**









## **FEATURES**

- Tamper-Resistant Field Adjustment
- Adjustable Ranges from 4 to 7500 PSI (0,3 to 517,1 Bar)
- Choice of 7 Electrical Terminations
- 1-1/4" Diameter
- Height as Small as 3"






## OVERVIEW

Available with seven electrical termination varieties, a choice of sensors, and several pressure connections, the 10 Series is designed to meet most requirements for a variety of OEM and industrial applications. Just 1-1/4 inches in diameter and as small as 3 inches high, this compact, cylindrical switch mounts wherever space is at a premium. A reliable and cost-effective switch, the 10 Series is ideal for applications with high settings and surges. Among the tough applications in which the product has proven itself are: mobile hydraulic units, compactors, balers and lube oil systems.

In addition to standard capabilities, modified designs or options are available to help you meet specific application requirements. Design flexibility allows for customized pressure connections, electrical terminations and pressure ranges. Consult UE for all product capabilities, order restrictions and special conditions.

## FEATURES

- cULus recognized, CE compliant to low voltage directive and pressure equipment directive
- Optional ATEX intrinsic safety compliance
- NPT or SAE threaded pressure connections
- Choice of 7 electrical terminations
- Optional leadwire/cable lengths
- Rugged and vibration resistant
- Proof pressures up to 12,000 psi (827 bar)



#### **Reading Office**

Cutbush Park, Danehill, Lower Earley, Reading, Berkshire. RG6 4UT. UK. Tel: +44 (0)118 9311188 Email: info@able.co.uk

#### **Aberdeen Office**

Unit 6 Airside Business Park, Kirkhill Industrial Estate, Dyce, Aberdeen. AB21 0GT. UK. Tel: +44 (0)1224 725999 Email: ab@able.co.uk

Internet: www.able.co.uk e-procurement: www.247able.com Registered in England No: 01851002 VAT No: GB 417 2481 61





### SPECIFICATIONS

STORAGE TEMPERATURE	-40 to 180°F (-40 to 82°C)
AMBIENT TEMPERATURE LIMITS	O to $160^{\circ}F$ (-18 to $71^{\circ}C$ ) with Buna-N construction; O to $180^{\circ}F$ (-18 to $82^{\circ}C$ ) with Viton® construction; set point shifts less than 1% of range for a $50^{\circ}F$ ( $28^{\circ}C$ ) ambient temperature change. Unit will operate down to $-40^{\circ}F$ ( $-40^{\circ}C$ ) but with reduced repeatability
MAX. MEDIA TEMPERATURE	200°F (93°C) with Buna-N sensor; 250°F (121°C) with Viton® sensor
SHOCK	Set point repeats after 50 G, 10 millisecond duration
VIBRATION	Set point repeats after 10 G, 5-500 CPS
ENCLOSURE CLASSIFICATION	Types C, D, E, F & G: Designed to meet enclosure type 4 requirements Types A & B: Not applicable
SET POINT REPEATABILITY	Models 10-12: $\pm$ 1% of full scale range; Models 13-16: $\pm$ 1.5% of full scale range
SWITCH OUTPUT	One SPDT
ELECTRICAL RATING	Rated to 5 A resistive and 5 A inductive (75% power factor), at 125 VAC & 250 VAC, $1/4$ HP; 5 A resistive and 3 A inductive at 30 VDC; 0.5 A resistive and 0.25 A inductive at 125 VDC; gold flashing over silver contact for loads down to 5 mA at 6 VDC, 2 mA at 12 VDC and 1 mA at 24 VDC
ENCLOSURE	Aluminum
WEIGHT	Type A: 5 oz.; Type B: 6 oz.; Type C: 6.5 oz.; Type D: 6 oz.; Type E: 12 oz.; Type F: 6.5 oz.; Type G: 12 oz.
ELECTRICAL CONNECTION	7 electrical terminations; Refer to "How to Order"
PRESSURE CONNECTION	Models 10-12: $1/8"$ NPT (male); Models 13-16: $1/4"$ NPT (male); optional SAE threads and other connections (see options list)
MOUNTING	Via pressure connection. Surface mounting bracket kit available for field installation. (see Options list)

Reading Office Cutbush Park, Danehill, Lower Earley, Reading, Berkshire. RG6 4UT. UK. Tel: +44 (0)118 9311188 Email: info@able.co.uk

Aberdeen Office

Aberdeen OfficeUnit 6 Airside Business Park, Kirkhill Industrial Estate,Dyce, Aberdeen. AB21 0GT. UK.e-procurement: www.247Tel: +44 (0)1224 725999Email: ab@able.co.ukVAT No: GB 417 2481 61







## **10 Series**



APPROVALS

#### UNITED STATES AND CANADA c **R**Us

UL Recognized, cUL Recognized Pressure: UL 508; CSA C22.2 No. 14, file # E42272

# 

(£x)

ATEX Directive (94/9/EC) II 1 G EEx ia IIC T6 (OPTIONAL – code M405) Tamb = -50°C to +60°C UL International DEMKO A/S (N.B.# 0539) Certificate # DEMKO 03 ATEX 0335063 EN 50014, 50020 & 50284

# Low Voltage Directive (LVD) (73/23/EC & 93/68/EEC)

Compliant to LVD Products rated lower than 50 VAC and 75 VDC are outside of the scope of the LVD The Low Voltage Directive does not apply to products for use in hazardous locations

#### Pressure Equipment Directive (PED) (97/23/EC) Compliant to PED

Products rated lower than 7.5 psi are outside the scope of the PED



#### RUSSIA Gosgortechnadzor Permit (OPTIONAL - code M406) 0ExialICT6

Tamb = -50°C to +60°C NANIO CCVE Certification Center Certificate # ROSS US.GB05.Bo2933 GOST 51330.0, 51330.1, 51330.10 & 51330.14

## MODEL CHART

Range Code	Adjustable Set Point Range Low end of range on fall High end of range on rise		Deadband Narrower deadbands may be expected at bottom of range		Over Range Pressure*		Proof Pressure * *	
	psi	bar	psi	bar (unless noted)	psi	bar	psi	bar
Buna-N diaphragm and O-ring with 1/8" NPT (male) brass pressure connection								
10	4 to 50	0,3 to 3,4	1 to 6	68,9 mbar to 0,4 bar	1000	68,9	3000	206,8
11	10 to 150	0,7 to 10,3	2 to 10	0,1 to 0,7	1500	103,4	3000	206,8
12	30 to 600	2,1 to 41,4	8 to 60	0,6 to 4,1	2500	172,4	3000	206,8
Stainless steel piston and Buna-N O-ring with 1/4" NPT (male) brass pressure connection								
13	100 to 1500	6,9 to 103,4	20 to 220	1,4 to 15,2	8000	551,6	10,000	689,5
14	180 to 3000	12,4 to 206,8	50 to 400	3,4 to 27,6	8000	551,6	10,000	689,5
15	400 to 4700	27,6 to 324,1	100 to 600	6,9 to 41,4	8000	551,6	10,000	689,5
16	4000 to 7500	275,8 to 517,1	400 to 950	27,6 to 65,5	10,000	689,5	12,000	827,4

\* Over Range Pressure: The maximum pressure that may be applied continuously without causing damage and maintaining set point repeatability.

\*\* Proof Pressure: The maximum pressure to which a pressure sensor may be occasionally subjected, which causes no permanent damage. The unit may require calibration (e.g., start-up, testing).

#### **Reading Office**

Cutbush Park, Danehill, Lower Earley, Reading, Berkshire. RG6 4UT. UK. Tel: +44 (0)118 9311188 Email: info@able.co.uk

#### Aberdeen Office

Unit 6 Airside Business Park, Kirkhill Industrial Estate, Internet: www.able.co.uk Dyce, Aberdeen. AB21 0GT. UK. Tel: +44 (0)1224 725999 Email: ab@able.co.uk





### HOW TO ORDER

Build a part number by selecting appropriate code for each feature category. Example: 10-B11\*M201

	10	В	11		M201		
	Series	Electrical	Range	Misc. Options			
	Designation	Termination					
		Туре	10	В	11	M201	
ORDERING CODE	DESCRIPTION			-			
SERIES DESIGNATION							
10	Designation for 10 Se	eries product line					
ELECTRICAL TERMINATION TYPI	E						
A	0.11" push-on termina	als. Mating terminals supplied					
В	0.25" push-on termin						
С		male) conduit connection; 20"	leads				
D E	NEMA 4; 20" leads	female) conduit connection; 5'	cablo				
F		DIN connector. Mating part no					
G	NEMA 4; 5' cable	on connector. Mating part ne	Jt supplied				
-							
RANGE							
10, 11, 12, 13	See model chart on p	age 4					
14, 15, 16							
MISCELLANEOUS OPTIONS							
M201	Factory set one switcl	n; specify increasing or decreas	ing pressure and set	point			
M277	Range indicated on n	ameplate in kPa or MPa, facto	ory selected				
M278	Range indicated on n	Range indicated on nameplate in kg/cm <sup>2</sup>					
M405	Intrinsic safety compl	Intrinsic safety compliance for European Union per ATEX standards					
M406	Intrinsic safety compl	Intrinsic safety compliance for Russia per Gosgortechnadzor standards					
M430	Cover lock						
M444	Paper ID Tag						
M446	Stainless steel ID tag	& wire attachment					
M449	Surface mounting bra	acket kit					
M511	1/4" NPT (male) 316	stainless steel pressure conne	ction				
M512	1/4" NPT (male) bras	ss pressure connection. NOT A	AILABLE ON MODE	LS 13, 14,	, 15, OR 16		
M540	Viton <sup>®</sup> construction. I	Deadbands and low end of ran	ige may increase (coi	nsult facto	ory). Wetted	parts include	
		d∕or O-ring plus standard pre					
M541	Ethylene propylene (EPDM) construction. Deadbands may increase (consult factory). Wetted parts include EPDM diaphragm and/or O-ring plus standard pressure connection material						
M550		ng (alcohol cleaning to remov			nection); Bui	na-N diaphra	
M925	5 5	E male brass pressure connect	ion				
M929		rread pressure connection					
62169-26	Surface mounting bra						
L040	•	OT AVAILABLE ON TYPES A, B	EEC				
L040 L060		OT AVAILABLE ON TYPES A, B					
L080							
		OT AVAILABLE ON TYPES A, B					
L100		NOT AVAILABLE ON TYPES A,					
			р, г				
L120 Viton® is a registered tra	12' leadwire/cable. I	NOT AVAILABLE ON TYPES A,E	3, F				

Viton® is a registered trademark of E.I. Dupont Company

#### **Reading Office**

Cutbush Park, Danehill, Lower Earley, Reading, Berkshire. RG6 4UT. UK. Tel: +44 (0)118 9311188 Email: info@able.co.uk

#### Aberdeen Office

Unit 6 Airside Business Park, Kirkhill Industrial Estate, Internet: www.able.co.uk Dyce, Aberdeen. AB21 0GT. UK. Tel: +44 (0)1224 725999 Email: ab@able.co.uk










IE

## DIMENSIONAL DRAWINGS

Dimensional drawings for all models may be found at www.ueonline.com



#### **Reading Office**

Cutbush Park, Danehill, Lower Earley, Reading, Berkshire. RG6 4UT. UK. Tel: +44 (0)118 9311188 Email: info@able.co.uk


#### Aberdeen Office

Unit 6 Airside Business Park, Kirkhill Industrial Estate, Internet: www.able.co.uk Dyce, Aberdeen. AB21 0GT. UK. Tel: +44 (0)1224 725999 Email: ab@able.co.uk





## **10 Series**




"A" Dimension Chart					
Models	Inches	mm	NPT		
A10-12	3.00	76.2	1/8"		
A13-16	3.31	84.1	1/4"		
B10-12	3.50	88.9	1/8"		
B13-16	3.81	96.8	1/4"		
C10-12	4.06	103.2	1/8"		
C13-16	4.38	111.1	1/4"		
D10-12	3.19	81.0	1/8"		
D13-16	3.50	88.9	1/4"		
E10-12	3.94	100.0	1/8"		
E13-16	4.25	108.0	1/4"		
F10-12	4.13	104.8	1/8"		
F13-16	4.44	112.7	1/4"		
G10-12	3.88	98.4	1/8"		
G13-16	4.19	106.4	1/4"		


NOTE: For full size drawings, please visit our web site @www.ueonline.com

### **PRESSURE CONNECTION DETAILS**


Model 10-12




Option M925



Model 13-16



Option M929





Cutbush Park, Danehill, Lower Earley, Reading, Berkshire. RG6 4UT. UK. Tel: +44 (0)118 9311188 Email: info@able.co.uk

#### Aberdeen Office

Unit 6 Airside Business Park, Kirkhill Industrial Estate, Internet: www.able.co.uk Dyce, Aberdeen. AB21 0GT. UK. Tel: +44 (0)1224 725999 Email: ab@able.co.uk

e-procurement: www.247able.com Registered in England No: 01851002 VAT No: GB 417 2481 61





7

#### **RECOMMENDED PRACTICES AND WARNINGS**

United Electric Controls Company recommends careful consideration of the following factors when specifying and installing UE pressure and temperature units. Before installing a unit, the Installation and Maintenance instructions provided with unit must be read and understood.

- To avoid damaging unit, proof pressure and maximum temperature limits stated in literature and on nameplates must never be exceeded, even by surges in the system. Operation of the unit up to maximum pressure or temperature is acceptable on a limited basis (e.g., start-up, testing) but continuous operation must be restricted to the designated adjustable range. Excessive cycling at maximum pressure or temperature limits could reduce sensor life.
- A back-up unit is necessary for applications where damage to a primary unit could endanger life, limb or property. A high or low limit switch is necessary for applications where a dangerous runaway condition could result.
- The adjustable range must be selected so that incorrect, inadvertent or malicious setting at any range point cannot result in an unsafe system condition.
- Install unit where shock, vibration and ambient temperature fluctuations will not damage unit or affect operation. When applicable, orient unit so that moisture does not enter the enclosure via the electrical connection. When appropriate, this entry point should be sealed to prevent moisture entry.
- Unit must not be altered or modified after shipment. Consult UE if modification is necessary.
- Monitor operation to observe warning signs of possible damage to unit, such as drift in set point or faulty display. Check unit immediately.
- Preventative maintenance and periodic testing is necessary for critical applications where damage could endanger property or personnel.
- Electrical ratings stated in literature and on nameplate must not be exceeded. Overload on a switch can cause damage, even on the first cycle. Wire unit according to local and national electrical codes, using wire size recommended in installation sheet.
- Do not mount unit in ambient temp. exceeding published limits.

#### LIMITED WARRANTY

Seller warrants that the product hereby purchased is, upon delivery, free from defects in material and workmanship and that any such product which is found to be defective in such workmanship or material will be repaired or replaced by Seller (Ex-works, Factory, Watertown, Massachusetts. INCOTERMS); provided, however, that this warranty applies only to equipment found to be so defective within a period of 24 months from the date of manufacture by the Seller. Seller shall not be obligated under this warranty for alleged defects which examination discloses are due to tampering, misuse, neglect, improper storage, and in any case where products are disassembled by anyone other than authorized Seller's representatives. EXCEPT FOR THE LIMITED WARRANTY OF REPAIR AND REPLACEMENT STATED ABOVE, SELLER DISCLAIMS ALL WARRANTIES WHATSOEVER WITH RESPECT TO THE PRODUCT, INCLUDING ALL IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE.

#### LIMITATION OF SELLER'S LIABILITY

Seller's liability to Buyer for any loss or claim, including liability incurred in connection with (i) breach of any warranty whatsoever, expressed or implied, (ii) a breach of contract, (iii) a negligent act or acts (or negligent failure to act) committed by Seller, or (iv) an act for which strict liability will be inputted to seller, is limited to the "limited warranty" of repair and/or replacement as so stated in our warranty of product. In no event shall the Seller be liable for any special, indirect, consequential or other damages of a like general nature, including, without limitation, loss of profits or production, or loss or expenses of any nature incurred by the buyer or any third party.

UE specifications subject to change without notice.

#### **U.S. SALES OFFICES**

United Electric Controls 31 Old Stage Road Hampton Falls, NH 03844 Phone: 617-899-1132 email: northeastsales@ueonline.com

United Electric Controls 28 N. Wise Ave. Freeport, IL 61032 Phone: 815-341-2588 email: midwestsales@ueonline.com

United Electric Controls 1022 Vineyard Drive Conyers, GA 30013 Phone: 770-335-9802 email: southeastsales@ueonline.com

United Electric Controls 5829 Grazing Court Mason, OH 45040 Phone: 513-535-5486 email: midatlanticsales@ueonline.com

United Electric Controls 102 Salazar Court Clayton, CA 94517 Phone: 925-408-5997 email: westcoastsales@ueonline.com

United Electric Controls 27 Summit Terrace Sparta, NJ 07871 Phone: 973-271-2550 email: easternsales@ueonline.com

United Electric Controls 4306 Whickham Drive Fulshear, TX 77441 Phone: 832-457-6138 email: southwestsales@ueonline.com

#### CANADA

EASTERN 68 Mosley Crescent Brampton, Ontario Canada L6Y 5C8 Phone: 905-455-5131 FAX: 905-455-5131

WESTERN 148 Silver Ridge Close N.W. Calgary, Alberta Canada T3B 3T4 Phone: 403-247-3724 FAX: 403-247-3724

## UNITED ELECTRIC CONTROLS

180 Dexter Avenue, P.O. Box 9143 Watertown, MA 02471-9143 USA Telephone: 617 926-1000 Fax: 617 926-2568 http://www.ueonline.com

#### **Reading Office**

Cutbush Park, Danehill, Lower Earley, Reading, Berkshire. RG6 4UT. UK. Tel: +44 (0)118 9311188 Email: info@able.co.uk

#### Aberdeen Office

Email: ab@able.co.uk

Unit 6 Airside Business Park, Kirkhill Industrial Estate, Internet: www.able.co.uk Dyce, Aberdeen. AB21 0GT. UK. Peri- ±44 (0112/24 725999 Begistered in England No

Internet: www.able.co.uk e-procurement: www.247able.com Registered in England No: 01851002 VAT No: GB 417 2481 61

#### **INTERNATIONAL OFFICES**

CHINA

United Electric Controls, *Shanghai Office* Room 1011, 10th Flr, Huai Hai Zhonghua Building No. 885, Renmin Road, Luwan District Shanghai 200010, P.R. China Phone: +8621-6255 8059 email: chinasales@ueonline.com

United Electric Controls, *Beijing Office* Room 1006, Jainhao International Bldg. Block D, No. 116 Zizhuyuanlu, Haidian District Beijing, China 100089 Phone: +86-10-5893-0518 email: beijingsales@ueonline.com

EASTERN EUROPE & SCANDINAVIA United Electric Controls 05-806 Komorow Kujawska 5, Poland Phone: +48 22 499 4804 email: easterneuropesales@ueonline.com

GERMANY

United Electric Controls An Der Zentlinde 21 D-64711 Erbach, Germany Phone: 496-062-7400 email: europeansales@ueonline.com

INDIA

United Electric Controls House no. 7, Kamalkunj Society Nizampura, Baraoda (Gujarat), India Phone: +91 (-265) -2788654 email: indiasales@ueonline.com

ASIA-PACIFIC

United Electric Controls, Far East No. 1-2-2, 2nd Floor Jalan 4/101C Cheras Business Centre Batu 5, Jalan Cheras 56100 Kuala Lumpur, Malaysia Phone: 603-9133-4122 email: fareastsales@ueonline.com

MEXICO

United Electric Controls Zacatecas # 206, Suite 20 Col Guadalupe CP 89120 Tampico, Tamaulipas Mexico Phone: 833-217-5201 email: latinamericasales@ueonline.com

RUSSIA

United Electric Controls, Moscow Elninskaya str., 15-140 Moscow, 121552, Russia Phone: +7 (495) 792-88-06 email: russiansales@ueonline.com